

**CALLED MEETING
SEPTEMBER 28, 2012**

The Water Committee of the Washington City Council met on Friday, September 28, 2012, 10:30 AM in the Council Chambers of City Hall to discuss generator options at the water and wastewater treatment plants. Mayor Ames Barnett presided.

Present were: Mayor Barnett, council members Scarborough and Rainey, City Administrator Eskew, City Clerk Danner, Electric Superintendent Mike Hardy and OMI Operations Manager John Scott.

Committee members and staff discussed the feasibility of putting generators at the Skull Shoals water treatment plant and the wastewater treatment plant.

In the event of a major power outage and/or storm there is only storage at the wastewater treatment plant for some 3 to 4 hours. It was noted that anything over 10,000 gallons is considered a major spill. Discussed was also the fact that it may take two generators to run all seven motors at once at the treatment plant.

At the Skull Shoals water plant the size requirement of the generators was discussed.

City Administrator Eskew will contact J & T Service for assistance with size and design requirements and John Scott will discuss with OMI possible assistance with design and financing.

ADJOURNMENT: Meeting adjourned at 11:10 AM.

_____ MAYOR

_____ CLERK